



Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate	Licence Number	SKM 9921/2
	Issued	8/2/2016

Annual collector output kWh/module													
Collector name	Location and collector temperature (T _m)												
	Athens			Davos			Stockholm			Würzburg			
	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	
EPI 20	1.519	1.061	649	1.152	767	439	846	538	301	918	577	317	
EPI 12	1.880	1.314	803	1.426	950	543	1.048	666	373	1.137	714	393	
EPI 25	2.061	1.440	880	1.564	1.041	596	1.148	730	408	1.246	783	430	
EPI 16	2.325	1.625	993	1.764	1.175	672	1.296	824	461	1.406	884	486	
EPI 54	2.634	1.841	1.125	1.999	1.331	761	1.468	933	522	1.593	1.001	550	

Collector mounting: Fixed or tracking Fixed; slope = latitude - 15° (rounded to nearest 5°)

Overview of locations				
Location	Latitude °	G _{tot} kWh/m ²	T _a °C	Collector orientation or tracking mode
Athens	38	1.765	18,5	South, 25°
Davos	47	1.714	3,2	South, 30°
Stockholm	59	1.166	7,5	South, 45°
Würzburg	50	1.244	9,0	South, 35°

G _{tot}	Annual total irradiation on collector plane	kWh/m ²
T _a	Mean annual ambient air temperature	°C
T _m	Constant collector operating temperature (mean of in- and outlet temperatures)	°C

The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool ScenoCalc. The collector output is calculated hour by hour according to the efficiency parameters from the Keymark test using constant collector operating temperature (T_m). A detailed description of the calculations is available at <http://www.sp.se/en/index/services/solar/ScenoCalc/Sidor/default.aspx>.

Central Offices: Kalavriton 4, 145 64 kifisia, Athens, Tel: +30 210 6233493-4 , Fax: +30 210 6233495, http://www.dqshellas.gr, e-mail: ioannisalexou@dqshellas.gr	Datasheet version: 4.06, 2014-01-15
	ScenoCalc version: Ver. 4.06 (Jan, 2014)